

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #2. Playground, Equipment & Athletic Fields
Repair corroded metal surface on playground equipment. Work order in place. [This is a repeat violation from last routine inspections 07/30/20, 10/29/20 & 10/13/21]. Playground is not being used.

CODE REFERENCE: 2. Playgrounds, Equipment and Athletic Fields. 5(2)(k) SREF. Playgrounds, equipment, and athletic fields where provided, shall be maintained in a safe and acceptable condition for the intended function. 5(2)(k)1 SREF. Play areas and athletic fields where fencing is provided shall comply with SREF, Section 5(2)(d). 5(2)(k)2 SREF. Pre-K, kindergarten, or day-care play areas, where provided, shall have direct access to and from their related classrooms or to a corridor providing immediate and safe access to the play area. 5(2)(k)3 SREF. Play areas and athletic fields, where provided, shall have either direct access from the facility without crossing roads, traffic lanes, drives, or parking lots, or have appropriate safety devices provided where access crosses parking areas or drives. 5(2)(a)8 SREF. The playground shall be graded and drained to prevent an unintentional accumulation of standing surface water and debris. 468.2.2 FBC. Playground and equipment shall be safe, structurally sound, vermin proof, and shall not have jagged or sharp projections. Playground equipment shall be anchored to prevent toppling or dislodgement. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

Violation #5. Maintenance & Repair

-Replace water-stained ceiling tiles inside #001 Music lab (used as computer room)
-Eliminate tripping hazard at hallway floor by AP's office. Observed uneven floor.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #12. Toilet Facilities

-Replace missing wall tile inside a stall at #110 Boys restroom.

-Repair/replace out-of-order toilet inside #003 restroom by Media Center. Work order in place.

CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Inspection Conducted By: Venus Fernandez (82515)
Inspector Contact Number: Work: (305) 623-3516 ex.
Print Client Name: Mr. Fayson-AP
Date: 12/14/2022

Inspector Signature:

Client Signature: